

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Date: 28/07/2026

It is certified that an inspection team headed by Dr. Madhukar
Devrao Madavi Medical Officer/Superintendent Group - 1 from
Primary health center Kalamb, Tq. Kalamb, Dist. Yavatmal - 445401. inspected
the CRAYONS ENGLISH MEDIUM SCHOOL KALAMB, Tq. Kalamb Dist.
Yavatmal, has safe Drinking Water facilities for the students and members of
staff of the institution and is maintaining the hygienic sanitation condition in the
school building & the campus as per the norms prescribed by the Central/State
Govt.

The above Certificate is valid for a period of (From 21/072026 to 20/072027)



Signature with Seal
Medical Superintendent
Rural Hospital Kalamb

Name : Dr. Madhukar Devrao Madavi

Designation : Medical Officer / Superintendent

To,

CRAYONS ENGLISH MEDIUM SCHOOL
KALAMB.

Tq. Kalamb, Dist. Yavatmal - 445401.

Principal
Crayons English Medium School,
Kalamb, Dist. Yavatmal (M.S.)

क्र. (आख्या/वे अ./घाटक)

558

(वि. वि., नमुना क्र. १) (वि. वि., नमुना क्र. १ पहा)

सर्वसा ११३ + १३
Gen. 113 m & c

मूळ प्रत

[अहस्तांतरणीय]

ORIGINAL COPY

(NOT TRANSFERABLE)

मालिका- 'ष'

शासनास केलेल्या प्रदानाची पावती
RECEIPT FOR PAYMENT TO GOVERNMENT


ठिकाण/Place यवतमाळ दिनांक/Date 16-06-2020 /20


Received from प्रताप के.पोंग ई.पी.स्कुल, कलंब

रु./Rs. 1880 रु. अक्षरी/Rs. in words एक हजार आठशे पंधरी

On account of घाणी जैविक व द्रव्याः तपासणी

रोखपाल किंवा लेखापाल
Cashier or Accountant


Signature and Designation
Chief Bacteriologist
Dist. Public Health Laboratory
Yavatmal


Principal
Crayons English Medium School,
Katamb, Dist. Yavatmal (M.S.)

District Public Health Laboratory, Yavatmal.

E-mail ID: dphlyvt@gmail.com

Phone : 07232-242946

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Dt. of Collection:- 16/06/26 Dt. of Receipt:- 16/06/26 -Dt. of Exam:- 16/06/26 onwards

(All the Analytical Results are in mgs. / liter except pH & Turbidity)

SR. NO.	TEST PARAMETER	1) Tubewell, Principal Crayons English medium school Kalam, Yavatmal	BIS Specifications 10500 : 2012 (Edn. 2.2) Normal Values	
			Desirable Limits	Permissible Limits
1	Physical Appearance	Clear	---	---
2	Odour	Odourless	Unobjectionable	---
3	Turbidity (N.T.U.)	0.13	1	5
4	pH Value	7.7	6.5 to 8.5	No Relaxation
5	Fluoride (as F)	0.11	1	1.5
6	Nitrates (as NO ₃)	28	45	No Relaxation
7	Total Dissolved Solids	738	500	2000
8	Iron (as Fe)	0.42	1.0	No Relaxation
9	Chlorides (as Cl)	162	250	1000
10	Total Hardness (as CaCO ₃)	476	200	600
11	Alkalinity (as CaCO ₃)	240	200	600
12	Permanent Hardness (As CaCO ₃)	236	-	-

- This Report is restricted only for the sample/s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.

REMARKS

- ✓ A) Water Sample No. is chemically fit/potable for drinking purposes on the basis of analyzed parameters only. However, this/these water source(s) can be used for drinking purposes only after proper disinfection and ascertaining its bacteriological quality.
- ✓ B) Sample No. ① Contain/s. TDS, TH and Alkalinity is/ are more than the Desirable limit as per BIS specifications. However, it can be used for drinking purposes only in the absence of alternate source and only after proper treatment & disinfection and ascertaining its bacteriological quality.
- ✗ C) Sample No. Contains /s. is/are more than the Permissible limit as per BIS specifications. Hence this / these water source(s) is / are Unfit for drinking purposes.

HEALTH SERVICES

LR. No - 262 / 2661 / 2026
Date: -

Forwarded With Compliments To:- Principal, Crayons English medium school, Kalam, Yavatmal

With reference to letter no. Dated - 16/06/2026

Principal
Crayons English Medium School,
Kalam, Dist. Yavatmal (M.S.)

(NA)
Chief Bacteriologist
Dist. Public Health Laboratory
Yavatmal

Government Of Maharashtra Public Health Department

DISTRICT PUBLIC HEALTH LABORATORY, YAVATMAL.

E-mail ID: dphlyvt@gmail.com

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER FOR DRINKING PURPOSE.

To :- Head Master ,Crayon's English Medium School, Kalamb.

Letter NO & Date: - , 16.06.2026

Lab Ref no.:- 387

Date of Collection: - 16.06.2026

Date of Receipt: - 16.06.2026

Date of Examination: -16.06.2026

S. N	Particular Of Samples	Results Of Examination		Remarks
		Bacteria Per 100ML		
		Coli forms	Thermotolarent	
1	Tube Well, Crayon's English Medium School, Kalamb	<16	03	Non-Potable

Note : Contaminated water sample should be properly chlorinated & rested for Bacteriological test and after confirmation, can be used for drinking Purpose.

Note :-1. It is presumed that the above water sample is collected by responsible person and from the same source mention in your letter.

2. This Report is restricted only for the sample submitted to this Laboratory.


HEALTH SERVICES

No./dphl/ytl/Bact./ L.R 387 /2510/2026

District Public Health Laboratory, Yavatmal

Dated :- 22/06/2026


Chief Bacteriologist
Dist.Public Health Laboratory
Yavatmal


Principal
Crayons English Medium School,
Kalamb, Dist. Yavatmal (M.S.)

Government Of Maharashtra Public Health Department

DISTRICT PUBLIC HEALTH LABORATORY, YAVATMAL,

E-mail ID: dphlyvt@gmail.com

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER FOR DRINKING PURPOSE

To :- Head Master ,Crayon's English Medium School, Kalamb.

Letter NO & Date: - , 16.06.2026

Lab Ref.no:- 388

Date of Collection: - 16.06.2026

Date of Receipt: - 16.06.2026

Date of Examination: -16.06.2026

S. No	Particular Of Samples	Results Of Examination		Remarks
		Bacteria Per 100ML		
		Coli forms	Thermotolarent	
1	Tube Well, Crayon's English Medium School, Kalamb	0	-	Potable

Note :Contaminated water sample should be properly chlorinated & rested for Bacteriological test and after confirmation, can be used for drinking Purpose.

Note :-1. It is presumed that the above water sample is collected by responsible person and from the same source mention in your letter.

2. This Report is restricted only for the sample submitted to this Laboratory.


HEALTH SERVICES

No /dph/yt/Bact./ L.R 388 / 2511 /2026

District Public Health Laboratory, Yavatmal

Dated :- 22/06/2026


Chief Bacteriologist
Dist.Public Health Laboratory
Yavatmal


Principal
Crayons English Medium School,
Kalamb, Dist. Yavatmal (M.S.)

District Public Health Laboratory, Yavatmal.

E-mail ID: dphlyvt@gmail.com

Phone : 07232-242946

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Dt. of Collection:- 16/06/2026 Dt. of Receipt:- 16/06/2026 -Dt. of Exam:- 16/06/2026 onwards
(All the Analytical Results are in mgs. / liter except pH & Turbidity)

SR. NO	TEST PARAMETER	1) R.O, Principal Crayon's English medium school Kalamb	BIS Specifications 10500 : 2012(Edn.2.2) Normal Values	
			Desirable Limits	Permissible Limits
1	Physical Appearance	clear	---	---
2	Odour	odourless	Unobjectionable	---
3	Turbidity (N.T.U.)	0-11	1	5
4	pH Value	7-1	6.5 to 8.5	No Relaxation
5	Fluoride (as F)	0	1	1.5
6	Nitrates (as NO ₃)	8	45	No Relaxation
7	Total Dissolved Solids	153	500	2000
8	Iron (as Fe)	0-11	1.0	No Relaxation
9	Chlorides (as Cl)	12	250	1000
10	Total Hardness (as CaCO ₃)	92	200	600
11	Alkalinity (as CaCO ₃)	94	200	600
12	Permanent Hardness (As CaCO ₃)	0	-	-

- This Report is restricted only for the sample/s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.

REMARKS

- A) Water Sample No. 1 is chemically fit/potable for drinking purposes on the basis of analyzed parameters only. However, this/these water source(s) can be used for drinking purposes only after proper disinfection and ascertaining it's bacteriological quality.
- B) Sample No. Contain/s..... is/ are more than the Desirable limit as per BIS specifications. However, it can be used for drinking purposes only in the absence of alternate source and only after proper treatment & disinfection and ascertaining it's bacteriological quality.
- C) Sample No. Contains /s..... is/are more than the Permissible limit as per BIS specifications. Hence this / these water source(s) is / are Unfit for drinking purposes.

HEALTH SERVICES

LR. No - 261/2660/2026
Date: -

Forwarded With Compliments To:- Principal, Crayon's
English medium

With reference to letter no. Dated - school, Kalamb
16/06/2026

(NA)
Chief Bacteriologist
Dist. Public Health Laboratory
Yavatmal

Principal

Crayon's English Medium School,
Kalamb, Dist. Yavatmal (M.P.)